

G100 Export Limitation Compliance Declaration

1. Site Details

Site Address: 99 Dno Street

Postcode: BH14 8Sb

MPAN: 2000021587351

2. Installer Details

Installer Company: Dorset Green Energy

Contact Name: Andy Goode

Accreditation: 71264

Telephone: 07708229968

Email: dorsetgreenenergy@outlook.com

3. System Configuration

Generation Type: R-11 (Solar PV)

Total Installed Capacity (kW): 30.0

Storage Present: Yes

Storage Capacity (kWh): 23.0

Phase: 3 Phase Supply / 3 Phase Inverter

4. Export Limitation Settings

Export Limit (Amps): 28.9

Export Limit (kW): 20.0

5. Limitation Type

☒ Inverter Integrated

☐ AC Coupled Device

6. Device Details

1. FOXESS Co., Ltd. AC3-Pro-15.0

FOXES/13920/V1 · 15.0 kW

2. FOXESS Co., Ltd. AC3-Pro-15.0

FOXES/13920/V1 · 15.0 kW

7. Export Limitation Scheme Description

The export limitation scheme operates by monitoring export at the point of connection and dynamically controlling generation output to ensure the declared export limit is not exceeded.

8. Fail-Safe Operation

The system operates in a fail-safe manner in accordance with G100 requirements. In the event of loss of communication, device failure, or system fault, export is reduced or prevented to ensure the export limit is not exceeded.

9. Supporting Documents

- ☒ Single Line Diagram attached
- ☐ Device datasheet attached
- ☐ ENA compliance evidence attached

10. Declaration

I confirm that the export limitation scheme complies with EREC G100 requirements and operates in a continuous and failsafe manner.

Signed:



Name: Andy Goode

Date: 29/06/2026